

TANÚSÍTVÁNY

Certificate



Tanúsítvány szám *Certificate No.*
HN 69291696

Oldal *Page*
0001

Jegyzőkönyv szám *Test Report No.*
CN23YD1J 002

Kiadás dátuma *Date of Issue*
2025-12-19

Tanúsítvány Tulajdonos *Certificate Holder*
ESYLUX GmbH & Co. KG
An der Strusbek 40
22926 Ahrensburg
Germany

Gyártóhely *Manufacturing Plant*
IBV Hungária Kft.
Csanyi út 71.
6100 Kiskunfélegyháza
Hungary

Vizsgálati Jel *Test Mark*



Tanúsítás alapjául szolgáló előírások *Tested according to*
EN IEC 60598-1:2021+A11
EN IEC 60598-2-1:2021

Tanúsított Termék (Termék azonosítás)
Certified Product (Product Identification)

Fixed Luminaire (Non-emergency light)

Type designation: OLIVIA-2 MPL 1200 OP 5300 840 IP66,
OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5,
OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5 MD,
OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5 DALI-2,
OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5 MD DALI-2,
OLIVIA-2 MPL 1500 OP 6300 840 IP66,
OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5,
OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5 MD,
OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5 DALI-2,
OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5 MD DALI-2

Trade Mark: ESYLUX
An der Strusbek 40
22926 Ahrensburg/Germany

Ratings: AC 220-240V, 50/60Hz;
ta: 45°C; Class I; IP66

See details in the Annex of this certificate.

A tanúsítvány a fenti termék típusra vonatkozik. A tanúsítvány a TÜV Rheinland InterCert Kft. Vizsgálati, Ellenőrzési és Tanúsítási Szabályzatán alapszik. A tanúsított termék megfelel a fenti vizsgálati előírásoknak, a sorozatgyártása ellenőrzött. A fenti ENEC jel használatának joga engedélyezett a tanúsított terméken. Ezt az Engedélyt egy ENEC egyezményt aláíró testület adta ki. This certificate refers to the above mentioned product type. The certificate is based on the Testing, Inspection and Certification Regulation of TÜV Rheinland InterCert Kft. The certified product fulfils the above listed requirements and its manufacturing is subject to surveillance. The right to use the above ENEC mark is permitted on the certified product. This Licence has been established by a body which is a signatory to the ENEC Agreement.

Tanúsító Szervezet
Certification Body

Eileen Feng

TÜV Rheinland InterCert Kft., MEEI Division – Product Certification
H-1143 Budapest, Gizella út 51-57., Hungary
www.tuv.com

Validity of certificate can be checked on www.CERTIPEDIA.com

Annex to certificate No. HN 69291696 0001

Page 1/2

Model list:

Item	Model	Rated power (W)	LED quantities (pcs)	CCT (K)	Weight (kg)	Dimension of product (mm) (LxWxH)	LED driver	DALI coupler	Motion sensor
1	OLIVIA-2 MPL 1200 OP 5300 840 IP66	32W	126	2700 - 4000	1.6	1174x102x 90	Xitanium 65W 200- 350mA 185V DS 230V EL	--	--
2	OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5	32W	126		1.6	1174x102x 90	Xitanium 65W 200- 350mA 185V DS 230V EL	--	--
3	OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5 MD	33W	126		1.7	1174x102x 90	Xitanium 65W 200- 350mA 185V DS 230V EL	--	HD02S-6 2
4	OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5 DALI- 2	33W	126		1.7	1174x102x 90	LL35HE-DA- 80-400	--	--
5	OLIVIA-2 MPL 1200 OP 5300 840 IP66 5x2.5 MD DALI-2	35W	126		1.8	1174x102x 90	LL35HE-DA- 80-400	DALI COUPLER E G2	HD02S-6 2
6	OLIVIA-2 MPL 1500 OP 6300 840 IP66	38W	156		1.9	1454x102x 90	Xitanium 65W 200- 350mA 185V DS 230V EL	--	--
7	OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5	38W	156		1.9	1454x102x 90	Xitanium 65W 200- 350mA 185V DS 230V EL	--	--

Certification Body


Eileen Feng

Date of issue:

Budapest, 2025-12-19

Annex to certificate No. HN 69291696 0001

Page 2/2

8	OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5 MD	39W	156		1.9	1454x102x 90	Xitanium 65W 200- 350mA 185V DS 230V EL	--	HD02S-6 2
9	OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5 DALI- 2	39W	156		1.9	1454x102x 90	LL50HE-DA- 80-550	--	--
10	OLIVIA-2 MPL 1500 OP 6300 840 IP66 5x2.5 MD DALI-2	41W	156		2	1454x102x 90	LL50HE-DA- 80-550	DALI COUPLER E G2	HD02S-6 2



TÜVRheinland[®]
Certification Body
Date of issue:

Budapest, 2025-12-19



.....

Eileen Feng