

a) Lieferant supplier's name		Maico Elektroapparate-Fabrik GmbH						
b) Modellkennung (Code) supplier model identifier (code)		WS 75 Powerbox H (0095.0646)						
c) Spezifischer Energieverbrauch specific energy consumption SEC class - climate zone „average“		SEC	kalt / cold	mittel / average		warm / warm		kWh /(m²·a)
			-78,39	-40,82		-16,67		
				A				
d) Typ typology			RVU	—	BVU	X		
			NRVU	—	UVU	—		
e) Art des eingebauten / einzubauenden Antriebes type of drive installed / intended to be installed			multi-speed	—	installed	X		
			VSD	X	intended to be instal.	—		
f) Art des Wärmerückgewinnungssystems (WRG) type of heat recovery system			rekuperativ / recuperative	X	regenerativ / regenerative	—	keines / none	
g) Temperaturänderungsgrad der WRG thermal efficiency of heat recovery		η _t	82				%	
h) Höchster Luftvolumenstrom maximum flow rate			70				m³/h	
i) Elektrische Eingangsleistung Ventilatorantrieb electric power input of the fan drive			24				W	
j) Schallleistungspegel sound power level		L _{WA}	39				dB[A]	
k) Bezugs-Luftvolumenstrom reference flow rate			0,0136111				m³/s	
l) Bezugsdruckdifferenz reference pressure difference			0				Pa	
m) Spezifische Eingangsleistung specific power input		SPI	0,25				W/(m³/h)	
n) Steuerungsfaktor und Steuerungstypologie control factor and control typology			CTRL	MISC		X-Value		
			0,65	1,21		2		
o) Innere Höchstlecklufrate / Äußere Höchstlecklufrate max. internal leakage rate / max. external leakage rate			innere / internal	3	äußere / external	3	%	
p) Mischrate mixing rate			2				%	
q) Lage und Beschreibung optische Filterwarnanzeige position and description of visual filter warning			LED - replace the filter continuously to preserve the device properties					
r) Anweisungen für Anbringung regelbarer AUL- / ABL-Gitter instructions to install regulated supply/exhaust grilles			—					
s) Internetadresse für Anweisungen zur Zerlegung/Demontage internet address for disassembly instructions			www.maico-ventilatoren.com					
t) Druckschwankungsempfindlichkeit Luftstrom airflow sensitivity to pressure variations at -20 Pa / +20 Pa			0				%	
u) Luftdichtheit zwischen innen und außen indoor / outdoor air tightness			—				m³/h	
v) Jährlicher Stromverbrauch annual electricity consumption		AEC	1,8				kWh/(m²·a)	
w) Jährliche Einsparung an Heizenergie annual heating saved		AHS	kalt/cold	mittel / average	warm / warm		kWh/(m²·a)	
			87,8	44,9	20,3			